

Annual Drinking Water Quality Report

City of Choteau
PWSID #00175
38 1st Avenue NW
PO Box 619
Choteau, MT 59422-0619
406-466-2510

We're very pleased to provide you with the annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. The water sources for the City of Choteau are a spring at the Main Pump House, springs at the Richem Pump House, and Upper and Lower Richem Springs. Our water has been classified by the State of Montana as ground water not under the direct influence of surface water. The Richem Pump House is the point of distribution, where it is chlorinated and distributed to the residences and businesses on the City's water system.

A source water delineation and assessment report was completed in March 2017. The report provides information on possible contamination sources, such as highways, railways, underground storage tanks and septic systems and rates the susceptibility of the City's water sources to these possible contaminants. The report is available for review at the City Office.

If you have any questions about this report or concerning your water, please contact Finance Officer Jodi Rogers or Public Works Director Mike Maples at 406-466-2510. We want our customers to be informed about their water utility. If you want to learn more, please call us for a personal tour of the City's water system or you may attend any of our regularly scheduled City Council meetings, which are held on the first and third Tuesday of each month at 7:00 p.m. at City Hall.

We're pleased to report that our drinking water is safe and meets federal and state requirements.

The City of Choteau routinely monitors for constituents in your drinking water according to Federal and State laws. The following table shows the results of any detects in our monitoring for the period of **January 1st to December 31st, 2016**. For constituents that are not monitored yearly, we have reviewed our records back to the last time the constituent was monitored.

We have monitored for lead and copper, and 90% or more of our samples have been in compliance with the Lead and Copper Rule

Parameter	Date	90th % value	Units	Action level	Source of Contamination
Lead	07/16/14	8	ppb	15	Household plumbing
Copper	07/16/14	0.17	ppm	1.3	Household plumbing

In the tables above and below you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to one minute in 2000 years or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Nephelometric Turbidity Unit (NTU)-nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Picocuries per liter (pCi/L)-picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS							
Contaminant	Violation Y/N	Sample Date	Highest Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants							
Nitrate + Nitrite as N	N	02/22/16	0.14	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Fluoride	N	02/22/16	0.3	ppm	4	4	Water additive which promotes strong teeth, erosion of natural deposits.
Volatile Organic Contaminants							
TTHMs (total trihalomethanes)	N	08/9/16	4.1	ppb	0	80	By-product of drinking water chlorination
HAA5 (Haloacetic acids)	N	08/9/16	1.0	ppb	0	60	Discharge from petroleum factories and By-product of drinking water chlorination
Radioactive Contaminants							
Gross Alpha	N	08/02/11	3.4	pCi/L	0	15	Erosion of natural deposits
Combined Radium	N	08/02/11	0.9	pCi/L	0	5	Erosion of natural deposits. .
Microbial Contaminants							
	Violation Y/N	Date	# Months Positive	MCLG	MCL	Likely Source of Contamination	
Total Coliform	N	Monthly	0	0	Present/ Absent	Soil Runoff	

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or are man made. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials.

Our system is pleased to announce we had no violations for 2016.

Asbestos: The City of Choteau analyzed for Asbestos in water collected on 2/29/12. The results were <0.20 MFL's. This is below the allowable limits.

TTHMs [Total Trihalomethanes]: Some people who drink water that contains trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer

Nitrates: As a precaution we always notify physicians and health care providers in this area if there is ever a higher than normal level of nitrates in the water supply.

Fluoride: Some people who drink water that contains fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

Copper: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Lead: Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

If present, elevated levels of Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Choteau is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about the lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Alpha Emitters: Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Combined Radium: Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water **IS SAFE** at these levels.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

This template is copyrighted with unlimited distribution and reproduction to NRWAs member state associations. This report was generated by Energy Laboratories, Inc – Helena, Montana-April 2016